

ANNEX A - PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (NORMATIVE)

(This annex is part of this Standard and is required for its use.)

BACnet Protocol Implementation Conformance Statement

Date: July 14th, 2003

Vendor Name: Custom Software Engineering

Product Name: Catalyst Pro

Product Model Number: n/a

Applications Software Version: 1.6 **Firmware Revision:** n/a **BACnet Protocol Revision:** 1

Product Description:

A Microsoft Windows based human-machine interface to Andover, BACnet, OPC, ModBus and other building automation and process control devices. Catalyst Pro conforms to the ASHRAE standard 135-2001.

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

List all BACnet Interoperability Building Blocks Supported (Annex K): DS-RP-A, DS-RP-B, DS-RPM-A, DS-RPM-B, DS-WP-A, DS-WP-B, DS-WPM-A, DS-WPM-B, DM-DDB-A, DM-DDM-B

Segmentation Capability:

- Segmented requests supported Window Size: 1024 (B/IP)
- Segmented responses supported Window Size: 1024 (B/IP)

Standard Object Types Supported:

An object type is supported if it may be present in the device. For each standard Object Type supported provide the following data:

- 1) Whether objects of this type are dynamically creatable using the CreateObject service
- 2) Whether objects of this type are dynamically deletable using the DeleteObject service
- 3) List of the optional properties supported
- 4) List of all properties that are writable where not otherwise required by this standard
- 5) List of proprietary properties and for each its property identifier, datatype, and meaning
- 6) List of any property range restrictions

Device: Read/Write all required and optional properties.

Analog Input: Read/Write all required and optional properties.

Analog Output: Read/Write all required and optional properties.

Analog Value: Read/Write all required and optional properties.

Binary Input: Read/Write all required and optional properties.

Binary Output: Read/Write all required and optional properties.

Binary Value: Read/Write all required and optional properties.

Multi-State Input: Read/Write all required and optional properties.

Multi-State Output: Read/Write all required and optional properties.

Multi-State Value: Read/Write all required and optional properties.

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): _____
- MS/TP slave (Clause 9), baud rate(s): _____
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): 300,1200,2400,4800,9600,19200,38400,57600
- Point-To-Point, modem, (Clause 10), baud rate(s): 300,1200,2400,4800,9600,19200,38400,57600
- LonTalk, (Clause 11), medium: _____
- Other: _____

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

Networking Options:

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
Does the BBMD support registrations by Foreign Devices? Yes No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4
- IBM™/Microsoft™ DBCS
- ISO 8859-1
- ISO 10646 (UCS-2)
- ISO 10646 (UCS-4)
- JIS C 6226

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:
